

Testing Report – PM₁₀ Enhanced Testing
Manufacturer & Air Sensor Name

Testing Organization
Contact Email / Phone Number
Date

Image of device
during chamber
evaluation

Testing Details

Testing Organization and Contact Information	
Testing organization (Name, Organization Type)	
Contact Information (Website, Phone Number, Email)	

PM ₁₀ FEM Monitor Information	
Manufacturer, model	
Sampling time interval	
Date of calibration	
Date of flowrate verification check	

Sensor Information			
Manufacturer, model			
Device firmware version			
Sampling time interval			
Sensor serial numbers	#1	#2	#3
Manufacturer listed detection limit			
Manufacturer listed longevity, lifespan			
Manufacturer listed drift			

Attached Documentation	
FEM monitor documentation	
Description, date(s) of maintenance activities	<input type="checkbox"/>
Sensor documentation	
Product specification sheet	<input type="checkbox"/>
Product manual	<input type="checkbox"/>
Description of parameters measured and units, and data flow	<input type="checkbox"/>
Data storage and transmission method	<input type="checkbox"/>
Data analysis/correction script and version	<input type="checkbox"/>
Testing chamber documentation	
Description of chamber, particle dispenser system, and particle sizer instrument	<input type="checkbox"/>

Effect of Relative Humidity (RH)

RH Monitor	Manufacturer	
	Model	

			Average RH (%)	Average T (°C)	Average FEM monitor PM ₁₀ concentration of test aerosol (µg/m³)	Average FEM monitor PM _{2.5} concentration (µg/m³)	PM _{2.5} /PM ₁₀ Ratio FEM monitor concentrations	Average sensor PM ₁₀ concentration (µg/m³)	Averaged influence of RH on sensor measurements (µg/m³)
Effect of RH	Initial Testing Conditions	Setpoint	40 ± 5	20 ± 1	60 ± 5%		≤ 0.4 ± 0.1		
		Measured Value							
	High RH Conditions	Setpoint	85 ± 5	20 ± 1	60 ± 5%		≤ 0.4 ± 0.1		
		Measured Value							

Testing Report – PM₁₀ Enhanced Testing
Manufacturer & Air Sensor Name

Testing Organization
Contact Email / Phone Number
Date

Image of device
during chamber
evaluation

Effect of Temperature (T)

T Monitor			Manufacturer						
			Model						
			Average RH (%)	Average T (°C)	Average FEM monitor PM ₁₀ concentration of test aerosol (µg/m³)	Average FEM monitor PM _{2.5} concentration (µg/m³)	PM _{2.5} /PM ₁₀ Ratio FEM monitor concentrations	Average sensor PM ₁₀ concentration (µg/m³)	Averaged influence of T on sensor measurements (µg/m³)
Effect of T	Initial Testing Conditions	Setpoint	40 ± 5	20 ± 1	60 ± 5%		≤ 0.4 ± 0.1		
		Measured Value							
	High T Conditions	Setpoint	40 ± 5	40 ± 1	60 ± 5%		≤ 0.4 ± 0.1		
		Measured Value							

60-Day Low Concentration Drift

			Average RH (%)	Average T (°C)	Average FEM monitor PM ₁₀ concentration of test aerosol (µg/m³)	Average FEM monitor PM _{2.5} concentration (µg/m³)	PM _{2.5} /PM ₁₀ Ratio FEM monitor concentrations	Average sensor PM ₁₀ concentration (µg/m³)	Sensor drift after 60 days (µg/m³)
60-Day Low Concentration Drift	Day 1 Date	Setpoint	40 ± 5	20 ± 1	15 ± 10%		≤ 0.4 ± 0.1		
		Measured Value							
	Day 60 Date	Setpoint	40 ± 5	20 ± 1	15 ± 10%		≤ 0.4 ± 0.1		
		Measured Value							

60-Day Mid Concentration Drift

			Average RH (%)	Average T (°C)	Average FEM monitor PM ₁₀ concentration of test aerosol (µg/m³)	Average FEM monitor PM _{2.5} concentration (µg/m³)	PM _{2.5} /PM ₁₀ Ratio FEM monitor concentrations	Average sensor PM ₁₀ concentration (µg/m³)	Sensor drift after 60 days (µg/m³)
60-Day Mid Concentration Drift	Day 1 Date	Setpoint	40 ± 5	20 ± 1	60 ± 5%		≤ 0.4 ± 0.1		
		Measured Value							
	Day 60 Date	Setpoint	40 ± 5	20 ± 1	60 ± 5%		≤ 0.4 ± 0.1		
		Measured Value							

Testing Report – PM₁₀ Enhanced Testing
Manufacturer & Air Sensor Name

Testing Organization
Contact Email / Phone Number
Date

Image of device
during chamber
evaluation

Accuracy at High Concentrations

		Average RH (%)	Average T (°C)	Average FEM monitor PM ₁₀ concentration of test aerosol (µg/m ³)	Average FEM monitor PM _{2.5} concentration (µg/m ³)	PM _{2.5} /PM ₁₀ ratio from FEM monitor concentrations	Average sensor PM ₁₀ concentration (µg/m ³)	Test averaged difference between sensor and FEM PM ₁₀ concentrations (µg/m ³)
Accuracy at High Concentrations	Setpoint	40 ± 5	20 ± 1	200 ± 5%		≤ 0.4 ± 0.1		
	Measured Value							
	Setpoint	40 ± 5	20 ± 1	300 ± 5%		≤ 0.4 ± 0.1		
	Measured Value							