



# **Economic and Environmental Assessment of Natural Gas Plants with Carbon Capture and Storage (NGCC-CCS)**

**Samaneh Babaee (ORISE) and Dan Loughlin  
U.S. EPA Office of Research and Development  
Research Triangle Park, NC**

**34<sup>th</sup> USAEE/IAEE North American Conference  
October 23-26, 2016 – Tulsa, Oklahoma**



## Outline

1. Motivation
2. Objectives
3. Approach
4. Preliminary results
5. Lessons learned

### Disclaimer

- The views expressed in this presentation are those of the authors and do not necessarily represent the views or policies of the U.S. Environmental Protection Agency.



## Motivation

- **Natural gas combined-cycle (NG) plants are promoted as a clean technology and a bridge to a low carbon future.**
- **NG plants have a number of advantages:**
  - Compared to new coal and nuclear plants
    - Relatively low investment cost
    - Easier to site and shorter build time
  - Lower NG prices in recent years due to the technological advancements in U.S. shale gas exploration
  - NG combined-cycle turbines (NGCC) can be retrofitted at a later date with carbon capture and sequestration (CCS)



## Motivation

- **NG plants have a number of challenges:**
  - Methane ( $\text{CH}_4$ ) leakage in the NG extraction, processing, transmission and distribution processes
  - Carbon dioxide ( $\text{CO}_2$ ) capture and sequestration results in a higher cost and energy penalty
  - The low  $\text{CO}_2$  content of gas from conventional NGCC plants yield difficulties in capture
  - Stringent  $\text{CO}_2$  reduction targets may make natural gas plants less attractive, even with CCS
- **The competitiveness of NGCC-CCS technologies may be affected by regional variations in fuel prices and access to renewables, as well as the presence and stringency of a  $\text{CO}_2$  cap.**



## Objectives

- How do various factors affect the competitiveness of NGCC-CCS and its potential role in climate change mitigation?
  - e.g., NGCC cost and efficiency, CO<sub>2</sub> capture cost and capture rate, fuel prices, methane leakage rate, stringency of greenhouse gas (GHG) reduction targets, nuclear hurdle rates, ...
- Do results change when we use a regional model?
  - Are there important underlying stories when we examine NGCC-CCS penetration at the regional level?




## Approach

- Used MARKet ALlocation (MARKAL) energy system model along with U.S. 9-region EPA database (EPAUS9r-2014), which can capture regional deployment of NGCC-CCS.
- Performed sensitivity analysis to explore conditions in which NGCC-CCS can compete with other power plants in each region through 2050 in response to:
  - 30% and 40% system-wide GHG cap
  - 50% system-wide GHG cap:
    - with variations in CCS retrofit characteristics (costs, capture rate, hurdle rate, efficiency penalty), NG prices, renewables availability and storage level, nuclear lifetime and cost, leakage rates... → 45 sensitivity runs
- Quantified energy consumption and CO<sub>2</sub> emissions as well as air pollutant emissions (nitrogen oxides (NO<sub>x</sub>), sulfur dioxide (SO<sub>2</sub>),...) for each region and scenario.



# Approach Energy system model: MARKAL

- **Bottom-up, technology-rich, and capture the full energy system:**
  - Technologies cost and performance estimates (efficiency, emission factors,...)
  - Technologies are connected via flow of energy commodities
  - End-use demands
  - Constraints (energy/emission regulations and policies, ...)
- **Optimization**
  - Identify the least-cost way to satisfy end-use demands over the model time horizon from 2005 to 2055



- **Model output**
  - Optimal installed capacity and utilization by technology
  - Marginal fuel prices
  - Emissions



# Approach Sensitivity parameters

## Contextual parameters:

- No lifetime extension on existing coal
- No lifetime extension on existing nuclear
- Hurdle rate for nuclear plant
- Natural gas price
- Methane leakage rate
- Maximum electrification of LDVs
- Wind and solar availability
- Battery storage capacity for renewables
- Electricity storage cost
- No CCS gas retrofit
- No gasification technologies
- No biomass gasification with CCS (BioIGCC-CCS)
- Hurdle rate for BioIGCC-CCS

## NGCC-CCS parameters:

### Cost


- Investment cost for NGCC-CCS
- CCS retrofit cost
- Hurdle rate for NGCC-CCS
- Hurdle rate for CCS retrofit
- CO<sub>2</sub> storage cost

### Performance: Efficiency

- Efficiency penalty for NGCC-CCS
- Efficiency penalty for CCS retrofit

### Performance: CO<sub>2</sub> capture rate

- CO<sub>2</sub> capture rate for NGCC-CCS
- CO<sub>2</sub> capture rate for CCS retrofit



Source: Kenarsari et al. (2013)





## Assumptions


Baseline and all GHG mitigation scenarios include:

- Cross-State Air Pollution Rule (CSAPR), Clean Power Plan (CPP) (regional caps derived from IPM mass-based analysis), and Corporate Average Fuel Efficiency (CAFE) standards for light duty vehicles
- Updated solar PV costs from the EPA's Integrated Planning Model (IPM)
- Simplified hurdle rates for power plants (new nuclear: 15%, coal and nuclear extension: 5%, and other new power plants: 10%)
- Upper bound capacity on new nuclear electricity generation is 5GW in 2020, which can grow up to 5% per year until 2055 (Max: 28GW new nuclear is built by 2055).
- The maximum share of electricity generation from wind and solar photovoltaics (PV) is limited to 50% of system-wide electricity production from 2010 through 2055.



# Assumptions

- Sensitivity analysis on 20 model parameters yielded a total of 45 MARKAL scenarios
- Discretized each parameter into very low, low, high, very high
- Ran MARKAL for individual parametric sensitivity
- For discussion purposes, focus on the results for:
  - No GHG policy
  - 50% GHG energy system-wide reduction by 2050, relative to 2005 (GHG50)






### Electricity Production by Technology



Scenario	2015	2030	2050
No Policy	3600	5480	7540
GHG30	3710	5370	5390
GHG40	3710	4990	2710
GHG50	3710	4830	2970






# Preliminary results

## Electricity generation under 50% GHG cap


**Lowest NGCC-CCS deployment: Very high natural gas price + GHG50**

**Highest NGCC-CCS deployment: No nuclear lifetime extension + GHG50**

**Electricity Production by Technology**



**Electricity Production by Technology**




- In low NGCC-CCS deployment: Higher coal with CCS, wind, solar thermal, and nuclear post 2040
- In High NGCC-CCS deployment: Higher central solar PV, NGCC (with CCS retrofit starting 2035)



# Preliminary results

## Electricity generation from NGCC-CCS under GHG50





# Preliminary results

## GHG cap vs. methane leakage rate in 2050

- As GHG cap and CH<sub>4</sub> leakage rate increase, NGCC-CCS deployment, NO<sub>x</sub> and CO<sub>2</sub> emissions, and NG consumption decrease, but solar and wind deployment increases, nuclear is fixed.

- As GHG cap increases, coal deployment, PM health damages, and SO<sub>2</sub> emissions decrease.

NGCC-CCS deployment (PJ)				
GHG cap	Methane Leakage rate			
	0.25%	1.00%	4.00%	7.00%
GHG30	3910	3440	2920	1230
GHG40	3830	2690	1660	1290
GHG50	3500	2990	1430	580

Coal deployment (PJ)				
GHG cap	Methane Leakage rate			
	0.25%	1.00%	4.00%	7.00%
GHG30	2030	2020	1830	1760
GHG40	1510	1450	1490	1780
GHG50	1060	1140	1580	1790

Solar and wind deployment (PJ)				
GHG cap	Methane Leakage rate			
	0.25%	1.00%	4.00%	7.00%
GHG30	5280	5800	8450	10980
GHG40	8740	10270	13390	15320
GHG50	13680	14410	16210	16310

Nuclear deployment (PJ)				
GHG cap	Methane Leakage rate			
	0.25%	1.00%	4.00%	7.00%
GHG30	3550	3550	3550	3550
GHG40	3550	3550	3550	3550
GHG50	3550	3550	3550	3550

PM-related health damages (billion \$)				
GHG cap	Methane Leakage rate			
	0.25%	1.00%	4.00%	7.00%
GHG30	1130	1130	1120	1100
GHG40	1050	1040	1000	1000
GHG50	980	980	980	1000

Total NO <sub>x</sub> (Kt)				
GHG cap	Methane Leakage rate			
	0.25%	1.00%	4.00%	7.00%
GHG30	6340	6330	6200	5940
GHG40	5980	5880	5530	5270
GHG50	5080	5020	4980	4810

Total CO <sub>2</sub> (Mt)				
GHG cap	Methane Leakage rate			
	0.25%	1.00%	4.00%	7.00%
GHG30	4210	4090	3740	3550
GHG40	3610	3520	3260	3070
GHG50	3170	3090	2870	2710

Total natural gas consumption (PJ)				
GHG cap	Methane Leakage rate			
	0.25%	1.00%	4.00%	7.00%
GHG30	29140	28260	23400	19140
GHG40	25170	22450	18180	15290
GHG50	20370	19100	15840	13640

Water consumption (trillion gallon)				
GHG cap	Methane Leakage rate			
	0.25%	1.00%	4.00%	7.00%
GHG30	1460	1470	1310	1190
GHG40	1360	1260	1220	1290
GHG50	1290	1290	1350	1530


Total SO <sub>2</sub> (Kt)				
GHG cap	Methane Leakage rate			
	0.25%	1.00%	4.00%	7.00%
GHG30	2140	2150	1980	1800
GHG40	1430	1360	1240	1310
GHG50	1180	1200	1200	1300



## Preliminary results

### Regional NGCC-CCS adoption under GHG50

The projected range of NGCC-CCS deployment across 45 scenarios in 2050




- R3 has the widest range of NGCC-CCS adoption with very low influence from different scenario parameters.
- The NGCC-CCS deployment in R1, R8, and R9 is negligible.



## Preliminary results

### Regional NGCC-CCS adoption under GHG50

The typical range of NGCC-CCS deployment across 45 scenarios in 2050



- Variation in scenarios parameters has the minimal effect on NGCC-CCS deployment in R2 and R4.
- R5 has higher NGCC-CCS deployment than R7, but the typical range of NGCC-CCS adoption is higher in R7.





## Lessons learned

- Mild GHG cap leads to higher NGCC-CCS deployment in later time periods, while stringent GHG cap results in lower NGCC-CCS deployment starting earlier in the model time horizon.
- Under 50% GHG cap and at the national level in 2050:
  - Highest NGCC-CCS deployment scenario: no nuclear lifetime extension
  - Lowest NGCC-CCS deployment scenario: very high NG price
    - The main trade-off is between nuclear and NGCC-CCS plants
  - Uncertainty in CH<sub>4</sub> leakage rates result in the largest range of NGCC-CCS adoption.
- Increased GHG cap and methane leakage rate result in:
  - Decrease in NGCC-CCS deployment, NO<sub>x</sub> and CO<sub>2</sub> emissions, and NG consumption
  - Increase in electricity generation from renewables
  - Fixed electricity production from nuclear power plants
- At the regional level, the minimum deployment of NGCC-CCS is seen in R1, R8, and R9; the widest range of NGCC-CCS adoption is associated with R3; NGCC-CCS deployment in R2 and R4 is the least responsive to variations in scenario parameters.



## Next steps

- **Add other scenario parameters:**
  - **Change the methane leakage rate over time**
  - **CO<sub>2</sub> leakage from CO<sub>2</sub> storage sites**
  - **Assume NGCC with CCS retrofit as a baseload power plant**
- **Examine the effects of including emissions associated with CO<sub>2</sub> transport through pipelines, trucks (gasoline, diesel, natural gas, ... )**
- **Examine the role of NET Power gas plant in our analysis**
- **Develop nested sensitivity analysis**



# Questions?

Contact information:

Samaneh Babaee, Ph.D.

ORISE Postdoctoral Fellow at the U.S. EPA

[Babaee.Samaneh@epa.gov](mailto:Babaee.Samaneh@epa.gov)